

## S.D. Water Testing Laboratory, Gandhi Nagar

Near CDA Office, Jeevan Nagar, Narwal Pain, Satwari. Pin-180003  
9682195320

## Test report

Sample ID

U459033L1438S397016'

## User Information

Name

Principal Jodhmal public school jammu

Mobile:

9419191503

Email:

Jodhamalpublicschool@gmail.com

Pin  
Code:

180011

Full  
Address:

House No- Channi himmat,jammu by pass road,jammu,Village- ,Gram Panchayat-CHOWADI, Block- SATWARI,District- JAMMU,State- JAMMU &amp; KASHMIR

## Sample description

Source  
of  
Sample:

Tube well / Bore well

Village:

CHOWADI

Gram  
Panchayat:

CHOWADI

Block:

SATWARI

District:

JAMMU

State:

JAMMU &amp; KASHMIR

Address:

Channi himmat,jammu by pass road,jammu Channi 180011

Remarks:

ThePrincipal,Jodhamal public school jammu

Latitude:

32.683624

Longitude:

74.903951

Date &amp; time of sample collection

17.02.22 | 02:30 PM

Date &amp; time of sample received in lab

17.02.22 | 02:40 PM

Date &amp; time of sample analysed

19.02.22 | 10:58 AM

Date &amp; time of report generation

19.02.22 | 11:05 AM

# Test results

Report no

3970161

S. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
1	Turbidity*	NTU	1	5	0	Fit
2	pH*	NA	6.5-8.5	No Relaxation	6.8	Fit
3	TDS*	Milligram/liter	500	2000	56.3	Fit
4	Fluoride (as F)*	Milligram/liter	1	1.5	0.5	Fit
5	Nitrate (as NO <sub>3</sub> )*	Milligram/liter	45	No Relaxation	10	Fit
6	Calcium (as Ca)*	Milligram/liter	75	200	70	Fit
7	Total Hardness (As CaCO <sub>3</sub> )*	Milligram/liter	200	600	200	Fit
8	Iron (As Fe)*	Milligram/liter	1	No Relaxation	0.05	Fit
9	E. coli*	CFU/100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0	Fit

**Note:**

- 1)\*indicates parameters that are not NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

Authorised signatory  
Gurmeet Kour

**Jal Jeevan Mission aims at potable tap water supply to every home**

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.